



Oil & Natural Gas Corporation Ltd
I/C HR/ER, Cambay Asset
P.O Kansari, Khambhat -388 630

Date: 24.10.2018

No. - CBY/HR/KV School/2018-19/1

From: I/C- HR/ER, ONGC, Cambay Asset

To: Principal, KV, ONGC Cambay, Khambhat

School Building Safety and Fire & Safety Certificate

This is to certify that KV ONGC Educational building, (occupancy type - B having height less than 15 metre height without basement), requires only portable fire extinguisher and the same is provided in the School Premises by ONGC.

With regard to structural safety of the school building, it has been observed that there were some surface cracks and since the building is very old, it needs proper structural evaluation.

Jania Bakshi
24.10.2018
(Jania Bakshi)

HRE

[Signature]
11/06/2021
Principal
Kendriya Vidyalaya Cambay

[Signature] 14/06/2021
सभापति / उपसभापति
CHAIRMAN / NOMINEE CHAIRMAN
विद्यालय प्रबन्धक समिति
VIDYALAYA MANAGEMENT COMMITTEE
के.वी., ओ.एन.जी.सी. केम्बे.
K.V., O.N.G.C. CAMBAY